

महाराष्ट्र राज्य सार्वजनिक आरोग्य सेवा

जिल्हा आरोग्य प्रयोगशाला बुलढाणा

ई मेल : dphlbul@gmail.com

दुरध्वनी क्रमांक : 07262/299249

पाणी नमुन्याचा सूक्ष्मजीवीय अहवाल

प्रति, प्राचार्य, डॉ. भार. एन. लाहोरी कॉन्व्हेंट स्कूल, सुलतानपूर

पाठविणाऱ्याचे पत्र क्रमांक व दिनांक :- 02/05/2025

प्रयोगशाला संदर्भ क्रमांक :- 3590

नमुना घेतल्याचा दिनांक :- 02/05/2025

नमुना पोहोचल्याचा दिनांक :- 02/05/2025

परिक्षण सुरू केल्याचा दिनांक :- 02/05/2025

अ.क्र.	नमुन्याचे विवरण	परिक्षणाचे निष्कर्ष			इतर अभिप्राय
		प्रति १०० मि.ली. नमुन्यातील संभाव्य सुक्ष्मजंतूची संख्या			
		कोलीफॉर्म	थर्मोटॉलरंट जीवाणू	इ. कोलाय	
	प्राचार्य, डॉ. भार. एन. लाहोरी कॉन्व्हेंट स्कूल सुलतानपूर ता. केदार जि. बुलढाणा <u>शाकंतील पिण्याचे पाणी</u> शा.पा.क्र → 854388 शा.त.फी → 3401 दिनांक → 02/05/2025	आपले पत्र क्र. <u>निरंक/2025</u> दिनांक <u>02/05/2025</u> अन्वये प्राप्त पाणी नमुने अ.क्र. <u>00</u> ते <u>01</u> <u>पिण्यास योग्य आढळले आहेत.</u>			

अभिप्राय : पिण्यास अयोग्य पाण्यावर योग्य प्रमाणात क्लोरिनची प्रक्रिया केल्यानंतर व सुक्ष्मजीवीय पुनर्तपासणीनंतर पिण्यास योग्य असल्याची खात्री झाल्यानंतरच ते पाणी पिण्यासाठी वापरता येईल.

अभिप्राय : पिण्यास अयोग्य पाण्यावर योग्य प्रमाणात क्लोरिनची प्रक्रिया केल्यानंतर व सुक्ष्मजीवीय पुनर्तपासणीनंतर पिण्यास योग्य असल्याची खात्री झाल्यानंतरच ते पाणी पिण्यासाठी वापरता येईल.

अहवाल क्रमांक : 1444

दिनांक :- 07/05/25

प्रत सादर :-

- १) मा. जिल्हा आरोग्य अधिकारी, जिल्हा परिषद, बुलढाणा
- २) मा. जिल्हा शल्य चिकित्सक, सामान्य रुग्णालय, बुलढाणा
- ३) मा. गटविकास अधिकारी, पंचायत समिती,

मुख्य अणुजीव शास्त्रज्ञ
जिल्हा आरोग्य प्रयोगशाला, बुलढाणा

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. NP/718

Dated: 05/03/2025

It is certified that an inspection team headed by Vibha Warade

(Name of Officers with designation) from C.E.O PHED

inspected the DR. R. N. LAHOTI CONVENT SCHOOL, SULTANPUR

(Name & Address of the school) on 05/03/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1444 dated 02/05/2025

of Buldhana (PHED Lab) certified that the

DR. R. N. LAHOTI CONVENT SCHOOL Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one



Signature with Seal:

Name

Designation

Name & Address of the Office / Department : Lohar

P. M. C. Lonar

Chief Officer

M. C. Lonar

Co. Lonar

To

DR. R. N. LAHOTI
CONVENT SCHOOL, SULTANPUR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

R. N. W. D.
Principal
Dr. R. N. LAHOTI CONVENT SCHOOL
SULTANPUR, BULDHANA (MR)
Affiliation No - 1130324

PRESIDENT
Dr. R. N. LAHOTI CONVENT SCHOOL
SULTANPUR, Tq. LONAR Dist.
BULDHANA (MR)



महाराष्ट्र MAHARASHTRA अ.क्र. 9000 0 2024 0.6 / 5 / 2024 36AB 685522



मुद्रांक घेणाराचे नांव नवोदय शिक्षण क्रीडा व.सा.म.
राहणार सुलतानपूर
हरते असल्यास त्याचे नांव _____
मुद्रांक कशासाठी घेतला _____
बही _____

गुलाबराव श्रीराम मावळकर
मुद्रांक विक्रेता (दु.नि.का.लोणार)
ता.मं. १०/९८ कोड क्र. ६३०८००७
ता.लोणार जि. बुलडाणा




NOTARY
Appointed Govt. of India
Sultanpur Dist-Buldhana

**Maharashtra State Public Health Service
District Health Laboratory Buldhana**

Email : dphibul@gmail.com

Phone No :07262/299249



Microbial Report Of Water Sample

To, Principal, Dr. R. N. Lahoti Convent School, Sultanpur

Senders Letter Number and Date :- 02/05/2025

Laboratory Reference Number :- 3590

Date Of Sampling :- 02/05/2025

Date Of Arrival Of Sample :- 02/05/2025

Date Of Commencement Of Examination :- 02/05/2025

Sr. No.	Specimen Description	Examination Findings			Other Feedback
		Per 100 ML.Potential in the sample Number of Microbes			
		Coliform	Thermo Tolerant Bacteria	E. Coli	
1	Principal , Dr. R. N. Lahoti Convent School Sultanpur Tq. Lonar Dist Buldhana <u>Drinking Water in School</u> Government receipt number - 854388 Government inspection fee - 340 Rs Date : 02/05/2025	Your Letter No :- Nill / 2025 As.per Date:- 02/05/2025 Received Water Sample No :- 00 To 01 <u>Found To be fit to Drink</u>			
Comment :- Non-potable water can be used for drinking only after proper chlorination and after microbiological re-testing is confirmed as potable					

Report No :-1444

Date :-07/05/20

Copy Submitted To :-

- 1) Hon. District Health Officer, Zilla Parishad, Buldhana
- 2) Hon. District Surgeon Hospital, Buldhana
- 3) Hon. Group Development Officer, Panchayat Samiti

Chief Micro-Biologist
District Health Laboratory, Buldhana



AFFIDAVIT
Solemnly affirmed before me
By Dr. Rashid M. Agha
R/o Sultanpur Age 36yr
Tq. Lohan Dist Buldhana
Who is Identified by
Shri Dr. R. N. Lahoti
By whom know personally
Date 14/5/25



NOTARY
Appointed Govt. of India
Sultanpur Dist-Buldhana

NOTED & REGISTERED
Sr.No. 6 Page No. 2
Document Pages 1
Date : 14/5/25